Utah Department of Environmental Quality Division of Drinking Water

Public Water System Inventory Report

Run Date: 08/04/2011 11:55 am

Gal/Min

PWS ID: UTAH09005 Name: HATCH TOWN

Legal Contact HATCH Rating: Approved

MYRON BEN NEILSON Rating Date: 03/10/1980

Address: PO BOX 590 Activity Status: Active

HATCH, UT 84735

Phone Number: 435-735-4385

City Served (Area):

County: GARFIELD COUNTY

Gal/Day

System Type: Community

Last Inv Update: 06/01/2011

Activity Status Cd: Active

Last Snty Srv Dt: 07/21/2008

Total Dsgn Cap:

Surveyor: CHAD REEDER

Total Emerg Cap:

Oper Period: 1/1 to 12/31

Contacts

Contact			Phone Numbers							
Type	Name	Title	Title Office		Email Address					
AC	NEILSON, MYRON BEN		435-735-4364	435-735-4385						

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections	
Combined	Metered	0	13	
Residential	Metered	0	99	
			112 T	- otal Svc Connection

Storage

Total Storage: 200,000 GAL Number of Units: 1 Adequate Capacity: NO

No.	Name	Туре	Effective Volume	Constr Matri	Overflow Elev	Activity Status	Press'd
ST001	HATCH TANK	Ground	200,000 GAL	Concrete	7103	Α	NO

Treatment Plants

No.	Plant Name	Capacity (gal/day)	Status	Process
TP001	CHLORINATOR FOR EAST #4		1	

Distribution System

Pump Type	Total Dy	n Head	Pressure	Cross	Auhority
	ft H2O	P.S.I.	Adequate	Connection	Statement
			No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL NO 1 WEST (ABANDO	O Inactive	WL	8	50 GPM	25 GPM	Yes	GW	Other		
WS002	WELL NO. 2	Inactive	WL	8			Yes	GW	Permanent		
WS003	WELL NO. 3 (ABANDONED) Inactive	WL	6			Yes	GW	Permanent		
WS004	WELL NO 4 EAST	Active	WL	10	150 GPM	210 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS005	WELL NO. 5	Active	WL	10	413 GPM	400 GPM	Yes	GW	Permanent	1/1 to 12/31	

^{*}Reports measured flow for wells, approved design capacity for all other sources.